



Postal Address:  
 PO Box 4282  
 Dandenong South, Victoria 3164  
 Australia

Testing. Advising. Assuring.

<b>EWFA CERTIFICATE OF TEST</b>	<b>CERTIFICATE No : SFC 2311500.1</b> <b>Page 1 of 1</b>
---------------------------------	--

Report Sponsor	Certificate Issue Date
Profine GmbH Mülheimer Str. 26, 53840 Troisdorf, Germany	15/06/10

**Introduction**

The element of construction described below was tested by this laboratory on behalf of the test sponsor in accordance with the stated test standard and achieved the results stated below.

Referenced Report	Report Date	Test Standard
EWFA 2311500	28/05/2010	AS 1530.8.1: 2007 Sections 16 and 19

**Description and Performance of Test Assembly**



Test Specimen Arrangement	Test result
The test specimen comprised a 2400mm wide × 2400mm high PVC framed PremiDoor glazed sliding door system incorporating 26mm thick Viridian glazed system in both glazed elements. This system was installed within an insulated timber stud framed wall system, clad with 9mm compressed cement sheeting to the exposed side and 10mm thick standard plasterboard to the unexposed side.	<b>BAL: A-40</b>

**Notes**

**THIS CERTIFICATE IS PROVIDED FOR GENERAL INFORMATION ONLY AND DOES NOT COMPLY WITH THE REGULATORY REQUIREMENTS FOR EVIDENCE OF COMPLIANCE.**

Reference should be made to the relevant test report to determine the applicability of the test result to a proposed installation.

The results of these fire tests may be used to assess fire hazard, but it should be recognised that a single test method will not provide a full assessment of fire hazard under all conditions.

<b>TESTING AUTHORITY</b>	Exova Warringtonfire Aus Pty Ltd	
<b>Address</b>	PO Box 4282 DANDENONG SOUTH VIC 3164 Unit 2, 409-411 Hammond Road, DANDENONG VIC 3175	
<b>Phone / Fax</b>	+61 (0) 3 9767 1066 / +61 (0) 3 9767 1001	
<b>ABN</b>	81 050 241 524	
<b>Email / Home Page</b>	<a href="http://www.exova.com">www.exova.com</a>	
<b>Authorisation</b>	Prepared By:	Reviewed By:
	 C. M. McLean	 K. G. Nicholls